

Rinnai

Technical Bulletin 63 - Approved Products for Use in Rinnai Boiler Applications

The purpose of this technical bulletin is to provide an updated list of approved system cleaners, inhibitors, and antifreezes for use in hydronic plumbing systems utilizing Rinnai boilers.

APPROVED SYSTEM CLEANERS:

- Fernox F3 Cleaner
- Noble Noburst Hydronic System Cleaner
- Rhomar Hydro-Solv 9100
- Sentinel X400

NOTICE
<ul style="list-style-type: none">• System cleaners are not to be used in the boiler (use isolating valves at header assembly).• The Rinnai boiler must be closed off (valved off) from the rest of the system, or not connected, while cleaners are in the system.• When cleaning is complete, drain the system and then flush with clean water to remove any sediment.

APPROVED SYSTEM INHIBITORS:

- Noble Noburst AL Inhibitor
- Rhomar Pro-tek 922
- Sentinel X100

APPROVED SYSTEM ANTIFREEZES: *

*Please refer to the boiler's installation and operation manual for specific percentage of glycol permitted in the installation.

- Chem Frost 100%
- Fernox Alphi 11
- Hall-Chem Solar II
- Rechochem Recofreeze AL
- Rhomar RhoGard Mutli-Metal (AL safe)
- Sentinel X500
- Univar Vanfrost

Rinnai America Corporation • 103 International Drive, Peachtree City, GA 30269
Toll-Free: 1-800-621-9419 • Phone: 678-829-1700 • www.rinnai.us

©2020 Rinnai America Corporation. Rinnai America Corporation continually updates materials, and as such, content is subject to change without notice. Local, state, provincial, federal and national fuel gas codes must be adhered to prior to and upon installation.