



## Technical Bulletin 127 - Boiler Certification Announcement

The purpose of this Technical Bulletin is to announce the approval of 2 inch PVC venting and 3 inch W.C. minimum inlet gas pressure for specific Rinnai Boilers.

### Boilers Approved for 2 Inch PVC Venting

- Maximum equivalent vent run of 20 ft / 6.1 m
- All models below are for **both NG and LPG**
  - E50C/CR
  - E75C/CR
  - E110C/CR
  - E60SR
  - E85SR
  - E110SR
  - Q85S
  - Q130S
  - QP85
  - QP130

### Boilers Approved for 3 Inch W.C. Minimum Inlet Gas Pressure

- All models below are for **NG ONLY**
  - E50C/CRN
  - E75CRN
  - E110CRN
  - E60SRN
  - E85SRN
  - E110SRN
  - Q85SN
  - Q130SN
  - Q175SN
  - Q205SN
  - Q175CN
  - QP85N
  - QP130N



Rinnai America Corporation • 103 International Drive, Peachtree City, GA 30269

Toll-Free: 1-800-621-9419 • Phone: 678-829-1700 • [www.rinnai.us](http://www.rinnai.us)

©2016 Rinnai America Corporation. Rinnai America Corporation continually updates materials, and as such, content is subject to change without notice. Local, state, provincial, federal and national fuel gas codes must be adhered to prior to and upon installation.