



Technical Bulletin 126 - Duravent Approval for Rinnai Boilers

The purpose of this technical bulletin is to announce the certification of M&G Duravent PolyPro and PolyPro Flex for use with Rinnai Condensing Boilers.

M&G Duravent

The following Duravent products are approved for use with Rinnai boilers:

- 2¹/₃" diameter PPS (lengths and elbows)
- 2¹/₃" Twin Pipe Termination (2/3 PPS-HTPL)
- 2" and 3" Single Pipe Termination (2/3 PPS-HSTL)
- 2"x4" and 3"x5" Concentric Horizontal Termination Kit (2/3 PPS-HKL)
- 2"x4" and 3"x5" Concentric Vertical Termination Kit (2/3 PPS-VKL)
- 2¹/₃" Flex Chimney Lining Kit (2/3 PPS-FKL)
- 2¹/₃" Flex Pipe (2/3 PPS-FLEX XX)

MAXIMUM EQUIVALENT VENT RUN

BOILER TYPE	VENT TYPE			
	2 ¹ / ₂ "x4" Concentric	3 ¹ / ₃ "x5" Concentric	2" Flex	3" Flex
E Series	40ft	100ft	20ft	50ft
Q85S/Q130S/ QP85/QP130	40ft	100ft	20ft	50ft
Q175S/Q175C	*	80ft	*	40ft
Q205S	*	40ft	*	20ft

*Not permitted for this model

Rinnai America Corporation • 103 International Drive, Peachtree City, GA 30269

Toll-Free: 1-800-621-9419 • Phone: 678-829-1700 • www.rinnai.us

©2016 Rinnai America Corporation. Rinnai America Corporation continually updates materials, and as such, content is subject to change without notice. Local, state, provincial, federal and national fuel gas codes must be adhered to prior to and upon installation.