

When installing any Rinnai combi boiler (Q175C, E75C, and E110C) it is suggested that a MRIK-T or MRIK-S be installed on the domestic connections. This will allow for proper maintenance (flushing) of the plate heat exchanger.